



- PROJECT DATA:**
- PROJECT LOCATION: SOUTH OF LEWES
HUNDRED; LEWES & REHOBOTH
COUNTY; SUSSEX
STATE OF DELAWARE
 - NATURAL GAS
TEST PRESSURE: 150 P.S.I. MIN.
OPERATING PRESSURE: 100 P.S.I. MAX.
 - PROJECT INVOLVES THE FOLLOWING:
NEW MAIN: 4,680 L.F. 4" HDPE
NEW MAIN: 12,200 L.F. 2" HDPE
 - DESIGN IS IN ACCORDANCE WITH ANSI B31.8b AND
NATURAL GAS PIPELINE SAFETY ACT OF 1968
 - REFERENCES: DE DATAMIL, GOOGLE EARTH, TATMAN &
LEE ASSOCIATES, CUC
DRAWINGS

- GENERAL NOTES:**
- ALL CONSTRUCTION SHALL BE IN ACCORDANCE WITH
CUC CONSTRUCTION STANDARDS (LATEST REVISION).
 - CONTRACTOR TO PROVIDE CUC WITH AS-BUILT
INFORMATION WITHIN 2 WEEKS AFTER COMPLETION OF
PROJECT.
 - CONTRACTOR SHALL PROVIDE ALL FIELD INFORMATION
ON THE PLANS; USE 8 1/2 X 11 SHEETS IF ADDITIONAL SPACE
IS REQUIRED. ALL INFORMATION (PLANS AND ANY
ADDITIONAL SHEETS) SHALL BE PROVIDED TO CUC.
 - CONTRACTOR TO NOTE ALL FIELD CHANGES ON PLANS.
 - CONTRACTOR SHALL NOTIFY CUC ENGINEERING
DEPARTMENT BEFORE CHANGING LOCATION OF GAS
MAIN CLOSER TO THE R-O-W AS SHOWN ON THE
DRAWINGS.

- CONSTRUCTION NOTES:**
- NEW GAS MAIN SHALL HAVE 36" OF COVER MINIMUM, BUT
NO MORE THAN 42" OF COVER UNLESS DIRECTED BY
CUC. DEPTHS ARE TO BE NOTED ON AS-BUILTS.
 - PAVED AREAS SHALL BE BORED, MOLED, OR
DIRECTIONAL DRILLED UNLESS OTHERWISE SPECIFIED.
 - ALL DISTURBED AREAS, INCLUDING DRIVEWAYS, SHALL
BE RESTORED TO PRE-CONSTRUCTION CONDITIONS.
 - CONTRACTOR IS RESPONSIBLE FOR GATHERING ANY
ADDITIONAL INFORMATION NEEDED TO COMPLETE WORK
DURING THE BID PROCESS.
 - ADHERE TO THE LAW AND CALL MISS UTILITY AT
800-282-8555 TWO FULL WORKING DAYS BEFORE YOU DIG
 - CONTRACTOR SHALL NOTIFY CUC PROJECT MANAGER
MINIMUM 72 HOURS IN ADVANCE OF INTENT TO WORK
EVENINGS OR WEEKENDS.



DATE	REVISION				BY

FIELD INSPECTION	YES	NO	N/A	INITIAL	DATE
PIGGED LINE			-		
OBSERVED PRESSURE TEST			-		
PURGED LINE TO 100% GAS			-		
ALL TIE-INS COMPLETED			-		
LOCATE LINE FOR TRACE WIRE CONTINUITY			-		
CORRECTLY INSTALLED ALL LINE MARKERS AND TEST POINTS			-		
REMOVE ALL EXCESS MATERIAL FROM SITE			-		
PROJECT SITE CLEAN OF TRASH AND DEBRIS			-		
PROJECT SITE RESTORED TO PRIOR CONDITIONS			-		
ALL DISTURBED PAVING RESTORED TO COMPLYING SPECIFICATIONS			-		
(IF NO TO ANY OF THE ABOVE, PLEASE PROVIDE FURTHER EXPLANATION)					
OUTSTANDING ISSUES WITH PROPERTY OWNER					
OUTSTANDING ISSUES WITH GOVERNING AGENCY					
(IF YES TO THE ABOVE, PLEASE PROVIDE FURTHER EXPLANATION)					
DOCUMENTATION					
FIELD INSPECTION COMPLETED					
PRESSURE TEST INFO COMPLETED PROPERLY					
ALL TIE-INS COMPLETED AND DOCUMENTED					
LINE MARKERS AND TEST POSTS DOCUMENTED					
AS-BUILTS SUBMITTED					
FINAL INVOICE READY					
MAIN INFO					
MAIN RECORD					
SIZE					
MATERIAL					
LENGTH					
WALL THICKNESS / SDR					
START DATE					
END DATE					
CONTRACTOR / FOREMAN					
STENCIL LINE					
PRESSURE TEST RECORD					
PRESSURE TEST START DATE					
PRESSURE TEST END DATE					
START PRESSURE					
END PRESSURE					
START TIME					
END TIME					
TEST OK?					
FOREMAN					
** ATTACH PRESSURE CHART TO PLAN					
TIE-IN RECORD					
TYPE OF TIE-IN					
SIZE & MATERIAL OF MAIN TAPPED					
MANUFACTURER					
STENCIL LINE (IF AVAILABLE)					
TAPS MADE BY					
FOREMAN					
FUSER					
WELDER					
**PHOTO OR SKETCH REQUIRED FOR EVERY TIE-IN					
FOR STEEL, COMPLETE BELOW:					
COATED / TYPE					
CONDITION OF COATING		NONE	POOR	FAIR	GOOD
EXTERNAL CORROSION VISIBLE?		YES	NO		
INTERNAL CORROSION VISIBLE?		YES	NO		
P/S READING					
COUPON SAVED?					
MISS UTILITY INFO					
TICKET NO.					
RESPONSE					
MATERIALS LIST					
(LIST ALL MATERIALS USED, SIZE, AMT AND TYPE)					
** ATTACH ALL VALVE CARDS AND PROFILES TO THE PLAN					

POST CONSTRUCTION APPROVAL:		
PRINT NAME	TITLE	
SIGNATURE	DATE	
ENGINEERING DEPARTMENT AS-BUILT APPROVAL		
SIGN	DATE	



0100200400

GRAPHIC SCALE

SCALE: 1" = 200'

CHESAPEAKE UTILITIES

350 SOUTH QUEEN STREET • DOVER, DE 19904

NEW GAS MAIN

WOLFE POINTE SUBDIVISION

& GILLS NECK ROAD

LEWES, DE

DRAWN BY

JTC

04/09/14

APPROVED

PROJECT NO.

2014.066

SHEET 1 OF 5